



GLYNN COUNTY FINANCE DEPARTMENT

1725 REYNOLDS STREET, 3rd FLOOR - BRUNSWICK, GEORGIA 31520-6406

PHONE: (912) 554-7139; FAX: 1-888-272-5563 Email: jhagen@glynncounty-ga.gov

QUESTIONS AND ANSWERS TWO

January 26, 2022

Subject: Blythe Island Regional Park Freshwater Fishing Pier PROJECT FY22 IFB 22017

Thank you for your interest in this project. The original posting date was December 8, 2021 with a closing date of **February 1, 2022**.

The following questions were received and then passed on to the respective project manager for responses. The questions are in the questioner's own words. Unless otherwise noted, the responses to the questions are in the project manager's own words. If more questions arise due to the responses here, please email me as soon as possible with the question and I will pass it along for clarification and post all responses once I have them.

1. What does the minimum weight bearing capacity need to be for the pylon?
 - a. Found in section page 88, Part H, Section 2 of the IFB:

SPECIAL PROVISIONS/SCOPE OF WORK SPECIFICATIONS

Blythe Island Regional Park Freshwater Fishing Pier PROJECT FY22- IFB 22017

1. The pier shall be built upon either 8x8 square or 10" diameter marine grade posts.

2. Two pile, each 14 feet from the abutment, shall be installed for load testing by a qualified testing firm prior to the remaining deck construction. The pile shall have sufficient bearing to hold a minimum of 110#/sf of deck surface area per pile. Piles shall be driven a minimum of ten feet below the mudline.

2. The bid document for BIRP Freshwater fishing pier automatically uses the same pile system price for the main Bid as it does for the alternate aluminum material price (line 10). The aluminum pier will require far less piles than the wood construction. If we use the bid document as is it will not show the true cost savings for using the aluminum pier. Could this be revised?"
 - a. Yes. Will revise bid schedule and post today. Please see bid schedule "Revised Bid Schedule for Blythe Island Fishing Pier 1.26.22" in the documents section of the bid posting.

Kind regards,

Jason Hagen
Procurement Officer
Glynn County Board of Commissioners